# VOC Content Test Certificate

*Tuesday 23rd June 2026*

Supplier: SSANGKOM GLOBAL PTY LTD (29 ANNIE ST, Coopers Plains, QLD, 4108, Australia).

Product Name: SEALSUM SCREED ECO

Date Tested: 22nd June 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

| **Specification**<br>**Green Building Council of Australia**<br>**Green Star Design & As Built V1.3-13.1.1B**<br>**Green Star Interiors V1.3-12.1.1B** | **SEALSUM SCREED ECO** |
|---|---|
| **General Purpose Adhesives and Sealants Limit:**<br>**50 grams per litre** | **1 gram per litre as VOC content per material** |
| *We hereby certify SEALSUM SCREED ECO is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia* | |

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

**Issue Date: 23/06/2026** **Expiry date: 23/06/2031** **P26060043**